



NOTES:

1. ONE INSIDE DROP ALLOWED FOR 5' MANHOLE. A LARGER MANHOLE WILL BE REQUIRED FOR MORE.
2. PIPE SIZE FOR DROP TO EQUAL INFLOW SEWER PIPE SIZE.
3. MECHANICAL JOINT OR PUSH-ON FITTINGS, ALL BELL, TO BE USED.
4. SAW-CUT OR DRILL ALL HOLES FOR PIPE AND BOLTS.
5. DROP MANHOLE MANDATORY WHEN DIFFERENTIAL BETWEEN INVERTS IS GREATER THAN 20 INCHES.
6. STAINLESS STEEL STRAPS SHALL BE USED ON ALL DROPS GREATER THAN 5- FEET AT 18 INCH INTERVALS.



JRP
APPROVED BY:

WEC
DRAWN BY:

DATE: 08/04/2010

SANITARY SEWER INSIDE DROP MANHOLE

DURHAM COUNTY, NORTH CAROLINA
ENGINEERING DEPARTMENT

SCALE:
NTS

DETAIL NO.
DUCO - 013a