



NOTES:

1. PIPE CONNECTION DETAIL USED SHALL BE CONSISTENT WITH THE SPECIFIC PIPE SIZE, PIPE MATERIAL AND STRUCTURE.
2. FLEXIBLE CONNECTORS SHALL MEET THE REQUIREMENTS OF ASTM C923 SPECIFICATIONS FOR RESILIENT CONNECTORS BETWEEN REINFORCED CONCRETE MANHOLE STRUCTURES, PIPES AND LATERALS.



JRP
APPROVED BY:

WEC
DRAWN BY:

DATE: 03/05/2010

MANHOLE PIPE CONNECTION DETAIL BOOT TYPE - FLEXIBLE CONNECTION

DURHAM COUNTY, NORTH CAROLINA
ENGINEERING DEPARTMENT

SCALE:
NTS

DETAIL NO.
DUCO - 005